

# CERTIFICATE OF APPROVAL No CF 318

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products

The undermentioned products of

### **DORMA UK LIMITED**

Wilbury Way, Hitchin, Hertfordshire SG4 0AB Tel: 01462 477600 Fax: 01462 477601

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

#### **CERTIFIED PRODUCT**

PHA 2000 CONTUR Series
Panic Exit Devices and PHA
CONTUR Exit Pad
Emergency Exit Devices
and Associated
Accessories

#### **TECHNICAL SCHEDULE**

TS26 The Contribution of Panic Exit Devices to the Fire Resistance of Door Assemblies And TS31 The Contribution of Emergency Exit Devices to the Fire Resistance of Door Assemblies

Signed and sealed for and on behalf of CERTIFIRE

Sir Ken Knight

Chairman - Management Council

cil

Issued: 26<sup>th</sup> February 2003 Reissued: 28<sup>th</sup> March 2013

Valid to: 27th March 2018

Page 1 of 4



on valid when all so it is least all the soul valid when all the soul valid wh



### CERTIFICATE No CF 318 DORMA UK LIMITED

### PHA 2000 Series CONTUR Panic Exit Devices and PHA CONTUR Exit Pad Emergency Exit Devices and Associated Accessories

- 1. The Devices are generally all surface fixed.
- 2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section D of the Technical Standards (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
- This approval relates to the use of the family of exit devices with the following door assemblies:-

Latched and unlatched, door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 60 minutes (Codes TT, ITT, ITC and ITM).

Latched and unlatched, door assemblies consisting of metallic leaves with metallic frames having a fire resistance up to 240 minutes (Codes MM and IMM).

- 4. The exit devices are approved on the basis of:
  - i) Initial type testing to EN 1125 and EN 179 for mechanical properties
  - ii) Initial type testing to EN 1634-1 for the fire resistance performance of doorsets
  - iii) An appraisal against TS26 and TS 31
  - iv) Certification of quality management system to ISO 9001: 2000.
  - v) Inspection and surveillance of factory production control.
  - vi) On-going audit testing in accordance with EN 1125:1997 + A1: 2001 requirements and EN 179:1998 + A1: 2001 requirements
- 5. This approval is applicable only to the specified exit devices and relevant accessories when used with door assemblies of proven fire resistance (as defined by EN 1634-1) which have previously been successfully tested unlatched but with a CERTIFIRE approved door closer. Failure to install the device and accessories in the appropriate manner will invalidate this certificate of approval.
- 6. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Type-

Issued: 26<sup>th</sup> February 2003 Reissued: 28<sup>th</sup> March 2013 Valid to: 27<sup>th</sup> March 2018

Page 2 of 4 Signed



# CERTIFICATE No CF 318 DORMA UK LIMITED

### PHA 2000 CONTUR Series Panic Exit Devices and PHA CONTUR Exit Pad Emergency Exit Devices and Associated Accessories

7. The following table shows acceptable doorsets types and fire resistance periods:

|       | Approved Door Type |     |    |     |     |     |
|-------|--------------------|-----|----|-----|-----|-----|
| Class | MM                 | IMM | TT | ITT | ITM | ITC |
| FD20  | ✓                  | ✓   | ✓  | ✓   | ✓   | ✓   |
| FD30  | ✓                  | ✓   | ✓  | ✓   | ✓   | ✓   |
| FD60  | ✓                  | ✓   | ✓  | ✓   | ✓   | ✓   |
| FD120 | ✓                  | ✓   | ×  | ×   | *   | ×   |
| FD240 | ✓                  | ✓   | ×  | ×   | ×   | ×   |
| E 20  | ✓                  | ✓   | ✓  | ✓   | ✓   | ✓   |
| El 20 | ✓                  | ✓   | ✓  | ✓   | ✓   | ✓   |
| E 30  | ✓                  | ✓   | ✓  | ✓   | ✓   | ✓   |
| EI 30 | ✓                  | ✓   | ✓  | ✓   | ✓   | ✓   |
| E60   | ✓                  | ✓   | ✓  | ✓   | ✓   | ✓   |
| EI 60 | ✓                  | ✓   | ✓  | ✓   | ✓   | ✓   |
| E 90  | ✓                  | ✓   | ×  | ×   | *   | ×   |
| EI 90 | ✓                  | ✓   | ×  | ×   | *   | ×   |
| E 120 | ✓                  | ✓   | ×  | ×   | ×   | ×   |
| EI120 | ✓                  | ✓   | ×  | ×   | ×   | ×   |
| E240  | ✓                  | ✓   | ×  | ×   | ×   | ×   |
| El240 | ✓                  | ✓   | ×  | ×   | ×   | ×   |

See CERTIFIRE Technical Schedules for designation of doorset types i.e. IMM etc.

### **Scope of Approval:**

Any associated external access devices cannot be considered for installation onto timber doorsets.

M

Issued: 26<sup>th</sup> February 2003 Reissued: 28<sup>th</sup> March 2013 Valid to: 27<sup>th</sup> March 2018



# CERTIFICATE No CF 318 DORMA UK LIMITED

PHA 2000 CONTUR Series Panic Exit Devices and PHA CONTUR Exit Pad Emergency Exit Devices and Associated Accessories

### **Classification code**

The approval provides the following classifications:

In accordance with EN 1125

|--|

In accordance with EN 179

| 3 7 6 1 1 4 2 2 B |
|-------------------|
|-------------------|

#### **Further Information**

Further information regarding the details contained in this data sheet may be obtained from Dorma UK Ltd (Tel: 01462 477600).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

TV

Issued: 26<sup>th</sup> February 2003 Reissued: 28<sup>th</sup> March 2013 Valid to: 27<sup>th</sup> March 2018

Page 4 of 4 Signed